

**Sensor Extension Kit Required  
Part No. 821-0207-01 or 02  
Belden 27326AS Cable By Others.  
Rigid Conduit Is Not Required.**

The Bracket May Not Be Needed For Duct Mount Applications. Different Condulets May Be Used To Fit The Application Requirements

821-0207-02 Class I, Division 1 Remote Sensor Kit And Bracket For Use As Required By Customer. Includes Poured Seal At Transmitter

**Do Not Install A Sensor Into The Sensor Housing For At Least 24 Hours So The PVC Cement Chemicals Will Not Damage The Sensor**

Part No. 821-0201-01 Or 06 (Qty 6)  
Sensor Filter Barrier

821-0209-01 Bayonet Adapter

7013442 Remote Gassing Fixture Is Optional. Includes Filter Barrier.

821-0209-05 PVC Adapter: Bayonet To 4 Inch Schedule 40 PVC Pipe

4 Inch PVC Reducing Tee, Saddle Or Socket Weld Flange By Others. Hose Clamps (By Others) Secure Saddle to Duct

**Sensidyne, LP**

**PVC Bushing Sensor Mounting Options**

Approvals

SCALE

None

SIZE

B

DWG. NO.

Sales Proposal

Do Not Scale Drawing