

Sensor Data Sheet

SENSALERT PLUS

SENSIDYNE®



Sulfur Dioxide – Filtered for H₂S (100 ppm Max.) Part No. 823-0218-23

Minimum Indicated Concentration	3 ppm
Repeatability	± 2% of Reading
Accuracy ¹	± 5% of Reading
Span Drift	< 10% change per year (typical)
Response Time (Rise) ²	T ₅₀ : < 5 seconds T ₉₀ : < 30 seconds, successive exposures
Recovery Time (Fall) ²	T ₁₀ : < 45 seconds
Temperature Range	-20° to 50°C (-4° to 122°F)
Humidity Range (continuous)	15–90 %RH, non-condensing
Humidity Range (intermittent).....	0–99 %RH, non-condensing
Pressure Range	Ambient atmospheric, ± 1 psi
Expected Sensor Life	3 years from Shipping Date
Recommended Calibration Flow Rate	500 to 1000 cc/min
Oxygen Requirement	1% by volume, minimum
SensAlert 4-Channel Controller.....	Not Compatible

¹ When unit is calibrated and serviced at recommended intervals.

² Room Temperature.

Cross-Interferences*

Gas	Gas Exposure	Sensor Output
Carbon Monoxide	60 ppm	+1 ppm
Chlorine	2 ppm	-1 ppm
Ethylene	100 ppm	None
Hydrogen	100 ppm	None
Hydrogen Chloride	5 ppm	None
Hydrogen Cyanide	2 ppm	+1 ppm
Hydrogen Sulfide	15 ppm	None
Nitric Oxide	35 ppm	None
Nitrogen Dioxide	1 ppm	-1 ppm

* Interference factors may differ from sensor to sensor, it is not advisable to calibrate with interferent gases.

Special Calibration Considerations:

Sulfur Dioxide – Filtered Sensor (PN° 823-0218-23)

Zeroing The Sensor

There are no special zeroing considerations for this sensor. Complete zeroing instructions are provided in Section 3.1 of the SensAlert^{Plus} User Manual or SensAlert ASI User Manual.

Span Calibration

It is recommended that this sensor be calibrated at the half-scale concentration of 50 ppm SO₂. There are no special calibration considerations for this sensor. Complete span calibration instructions are provided in Section 3.2 of the SensAlert^{Plus} User Manual or SensAlert ASI User Manual.

Test-on-Demand Cell

There is no Test-On-Demand cell available for this sensor.